

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 MAYO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	16	16	17	18	19	22	23	24	25	26	29	30	31	NOM-127/21	PROMEDIO	
TURBIEDAD	4.0	3.9	4.0	4.0	4.0	4.0	3.9	4.0	3.9	3.8	3.4	3.8	4.0	3.8	3.4	4.0	3.8	3.6	4.0	4.0	3.8	4.0	3.9	4.0	3.9	3.9
N.T.U.	7.6	7.2	7.6	7.4	7.5	7.5	7.2	7.5	7.3	7.0	7.3	7.3	7.2	6.9	7.4	7.2	7.2	7.1	7.0	7.1	7.0	7.0	7.2	6.5-8.5	7.2	
P.H.	114	110	108	108	112	118	112	108	114	128	132	118	106	106	120	116	118	112	110	112	96	100	130		113	
ALCALINIDAD TOTAL	364	370	362	360	364	374	380	384	362	380	400	422	376	368	386	336	362	368	372	354	370	416	400	500	375	
DUREZA DE CALCIO	194	198	190	186	188	190	198	196	186	210	210	210	208	176	180	196	202	220	206	206	240	196	202		199	
DUREZA DE MAGNESIO	170	172	172	174	176	184	182	188	176	170	190	212	168	192	206	140	160	148	166	148	130	220	198		176	
CLORUROS	198	183	190	194	210	234	232	244	238	230	248	232	210	212	218	218	218	220	232	244	230	250	250		223	
COLORO RESIDUAL	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.2	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.3	1.5	1.4	1.5	1.5	0.2-1.5	1.5	
SDT	778	804	690	665	646	702	724	718	720	748	773	726	684	657	645	623	611	997	987	806	769	821	846		745	
TEMPERATURA °C	25.2	24.3	24.5	25.9	26.3	26.8	25.8	23.6	26.2	26.6	26.7	25.3	23.9	26.5	26.8	26.1	25.9	25.2	28.1	27.6	25.5	27.5	27.9		26.0	

AUTORIZO:

Vo.Bo

IQ. TERESITA BARRÉNICE LOPEZ MELGAR
 JEFA DE LABORATORIO

BIOLOGO CARLEMMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx

