



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 MAYO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	PROMEDIO
TURBIDEZAD N.T.U.	30.9	32.8	26.8	22.8	25.7	26.8	24.4	27.8	18.6	26.0	24.0	21.8	21.5	23.6	32.9	21.6	17.0	17.6	24.0	21.8	22.5	18.1	18.3	23.8
P.H.	7.8	7.4	7.8	7.5	7.9	7.7	7.8	7.6	7.6	7.9	7.5	7.7	7.6	7.8	7.7	7.5	7.3	7.6	7.5	7.6	7.5	7.4	7.6	7.6
ALCALINIDAD TOTAL	116	114	112	108	106	110	112	114	116	120	118	116	128	112	124	138	134	142	118	130	114	104	128	119
DUREZA TOTAL	410	448	400	404	406	410	394	398	392	414	316	400	426	408	406	400	422	402	390	414	400	384	404	402
DUREZA DE CALCIO	188	242	200	206	190	188	180	188	184	200	178	228	182	216	202	204	192	204	190	178	176	180	170	194
DUREZA DE MAGNESIO	222	206	200	198	216	224	214	212	208	214	138	172	244	192	204	196	230	198	200	236	224	204	234	208
CLORUROS	256	243	246	234	254	250	234	248	236	270	158	244	236	230	244	230	246	254	260	252	226	236	244	240
SDT	805	880	801	795	770	788	778	784	788	792	986	738	735	720	704	696	689	894	888	845	739	713	899	784
TEMPERATURA OC	24.8	23.4	23.9	26.0	26.4	26.5	24.9	23.9	25.9	26.8	26.5	25.2	25.6	26.8	27.2	26.2	26.3	26.6	29.2	28.4	27.0	28.6	29.0	26.3

AUTORIZO:

IQ. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx

Vc.Bo.

BIOLOGO QUÍMICO ERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA