



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA RIO BRAVO
JUNIO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIDEZAD N.T.U.	13.5	10.3	11.8	10.0	9.4	11.3	9.7	10.4	12.0	10.6	15.6	18.2	21.3	27.6	28.2	27.4	33.2	26.6	29.3	23.7	21.5	23.3	18.4
P.H.	7.5	7.6	7.1	7.3	7.4	7.1	7.4	7.5	7.0	7.2	7.4	7.4	7.4	7.2	7.2	7.4	7.3	7.5	7.4	7.4	7.3	7.3	7.3
ALCALINIDAD TOTAL	146	144	120	120	124	122	110	126	134	130	120	136	96	84	116	102	90	94	90	86	80	76	111
DUREZA TOTAL	396	406	334	352	348	350	348	310	340	350	336	324	220	224	284	268	286	276	248	276	260	256	309
DUREZA DE CALCIO	180	210	170	166	178	172	172	180	190	190	188	172	110	120	130	134	120	140	120	152	116	120	156
DUREZA DE MAGNESIO	216	196	164	186	170	178	176	130	150	160	148	152	110	104	154	134	166	136	128	124	144	136	153
CLORUROS	318	320	284	204	198	190	188	225	246	235	218	206	120	92	90	88	90	100	86	80	106	130	173
SDT	908	857	704	622	720	669	675	788	805	800	706	660	682	527	448	433	425	400	387	380	370	360	606
TEMPERATURA OC	28.1	28.3	27.2	28.0	28.2	24.0	27.0	28.4	26.3	26.2	25.3	25.6	25.8	26.0	27.8	24.9	25.4	24.8	26.5	24.3	26.8	24.9	26.4

AUTORIZO:

I.O. TERESITA BERENICE LOPEZ MELGAR
JEFA DE LABORATORIO

Vo.Bo
BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA