



PLANTA POTABILIZADORA PASTOR LOZANO
 ANALISIS FISICOQUIMICOS
 AGUA CRUDA CANAL RODHE
 JUNIO 2023

RESULTADOS EN MG/L T

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	25.0	26.3	18.2	15.8	18.6	19.2	17.0	22.4	18.2	28.4	19.8	21.9	30.6	36.7	32.2	47.3	30.8	29.1	24.9	27.7	26.4	32.9	25.9
P.H.	7.8	7.7	7.3	7.0	7.7	7.6	7.7	7.5	7.5	7.6	7.5	7.6	7.7	7.7	7.5	7.5	7.6	7.7	7.7	7.9	7.8	7.7	7.6
ALCALINIDAD TOTAL	114	120	110	124	126	124	122	138	126	120	112	122	98	82	94	90	84	102	84	82	86	74	106
DUREZA TOTAL	386	416	350	388	376	368	360	350	390	392	390	394	354	384	364	376	340	378	396	370	372	368	376
DUREZA DE CALCIO	166	186	180	178	176	170	186	158	177	188	200	188	172	180	162	184	194	192	198	196	170	172	181
DUREZA DE MAGNESIO	220	230	170	210	200	198	174	192	213	204	190	206	182	204	202	192	146	186	198	174	202	196	195
CLORUROS	228	242	218	232	220	208	200	248	238	240	225	258	206	224	216	198	218	206	216	200	204	212	221
SDT	693	695	841	675	845	800	790	799	767	807	710	757	1245	965	784	773	774	710	691	685	660	662	779
TEMPERATURA OC	29.0	27.5	27.5	26.1	28.8	24.6	27.3	28.8	26.2	26.8	26.0	25.5	26.4	26.2	24.6	25.0	25.5	24.7	26.2	24.5	27.4	25.2	26.4

AUTORIZO:


 I.Q. TERESITA BERENICE LOPEZ MELGAR
 JEFA DE LABORATORIO

Vo.Bo.


 BIOLOGO QUIMICO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA