



**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANÁLISIS FÍSICOQUÍMICOS  
 AGUA CRUDA CANAL RODHE  
 JULIO 2023**

RESULTADOS EN MG/LT

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	PROMEDIO
TURBIEDAD N.T.U.	38.1	48.7	38.9	36.1	28.7	42.3	32.7	26.5	36.4	46.0	41.7	58.0	49.8	43.1	45.2	49.1	38.4	23.0	24.9	26.2	25.6	38.1
P.H.	7.6	7.7	7.7	7.7	7.4	7.5	7.5	7.4	7.4	7.6	7.7	7.7	7.8	7.9	8.0	7.9	7.9	8.0	7.9	8.0	7.7	7.7
ALCALINIDAD TOTAL	76	72	64	88	80	84	84	80	82	74	88	90	80	86	80	90	110	92	84	74	86	83
DUREZA TOTAL	382	377	384	364	370	352	350	360	356	360	380	386	390	392	390	420	424	432	420	420	366	385
DUREZA DE CALCIO	226	230	212	202	200	204	204	216	210	192	206	190	186	210	192	226	200	210	198	172	206	204
DUREZA DE MAGNESIO	156	147	172	162	170	148	146	144	146	168	174	196	204	182	198	194	224	222	222	248	160	180
CLORUROS	226	230	244	240	236	238	232	244	248	254	256	236	254	258	256	311	292	285	275	280	256	255
SDT	660	750	980	770	850	880	940	822	815	802	780	756	745	857	960	964	962	954	927	921	896	857
TEMPERATURA °C	24.5	24.7	25.8	25.3	26.3	25.6	25.1	28.5	26.3	28.3	28.5	28.1	28.7	28.2	27.9	30.2	29.4	27.2	29	29.2	28.0	27.4

AUTORIZÓ:

*Edna Soto Lozano*  
 IQ. EDNA MARISSA SOTO LOZANO  
 JEFA DE LABORATORIO

Vo.Bo.  
  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA