



**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANÁLISIS FÍSICOQUÍMICOS  
 AGUA CRUDA RIO BRAVO  
 AGOSTO 2023**

**RESULTADOS EN MG/LT**

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	21.4	19.3	24.8	28.1	22.1	29.5	27.8	25.6	25.5	25.6	23.0	21.4	24.5	25.0	30.3	30.5	24.2	20.3	22.3	24.9	22.1	23.8	24.2	24.6
P.H.	7.7	8.0	7.6	7.6	7.9	8.1	7.8	7.8	7.9	7.5	7.8	8.0	7.9	7.8	8.1	7.7	7.8	7.8	7.9	7.7	8.0	7.7	7.5	7.8
ALCALINIDAD TOTAL	90	88	84	78	94	74	106	104	102	88	100	106	94	80	98	92	88	84	86	72	100	94	80	91
DUREZA TOTAL	262	284	268	274	266	270	266	264	266	260	242	276	228	260	274	244	284	282	280	234	254	274	276	265
DUREZA DE CALCIO	160	144	114	160	156	164	156	140	154	144	144	156	132	150	166	130	180	156	120	134	148	172	164	150
DUREZA DE MAGNESIO	102	140	154	114	110	106	110	124	112	116	98	120	96	110	108	114	104	126	160	100	106	102	112	115
CLORUROS	124	128	126	136	130	108	100	114	118	118	112	106	120	110	124	102	106	104	108	120	110	112	136	116
SDT	469	446	428	445	510	433	424	416	460	620	550	470	451	430	454	449	436	477	476	572	510	499	506	475
TEMPERATURA °C	28.0	28.6	28.0	29.0	27.9	28.2	28.6	28.5	28.5	29.5	28.8	28.1	28.1	26.9	27.6	28.2	28.2	27.6	28.6	27.8	28.1	29.2	29.5	28.3

AUTORIZÓ:

*Edna Marissa Soto Lozano*  
 I.Q. EDNA MARISSA SOTO LOZANO  
 JEFA DE LABORATORIO

Vo.Bo.

*Guillermo Nava Lujano*  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA

*Glenda*