



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 AGOSTO 2023

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	26.6	23.7	23.4	27.5	27.4	27.9	30.6	32.4	26.3	28.2	30.3	31.3	33.2	32.8	33.5	26.8	31.4	37.0	30.8	27.6	45.2	67.7	29.9	31.8
P.H.	7.7	8.0	7.7	7.7	7.9	7.8	7.7	7.7	7.9	7.3	7.7	7.8	7.5	7.7	8.0	7.5	7.8	7.8	7.8	7.7	7.9	7.8	7.5	7.7
ALCALINIDAD TOTAL	80	74	68	60	80	76	118	90	88	84	88	88	82	82	80	84	80	70	76	74	116	126	100	85
DUREZA TOTAL	408	412	414	416	410	412	368	390	396	400	380	404	386	400	394	396	420	410	410	312	312	320	376	389
DUREZA DE CALCIO	220	208	204	214	220	200	200	260	196	190	180	182	194	214	214	210	236	218	182	160	204	180	224	205
DUREZA DE MAGNESIO	188	204	210	202	190	212	168	130	200	210	200	222	192	186	180	186	184	192	228	152	108	140	152	184
CLORUROS	266	284	282	270	242	256	242	260	248	260	260	250	258	268	242	238	260	252	256	162	128	188	248	244
SDT	844	812	778	754	894	770	761	749	839	1125	986	856	811	797	801	829	805	889	877	754	580	698	817	819
TEMPERATURA °C	28.0	28.7	28.2	28.9	27.6	28.7	28.6	28.6	28.8	30.0	28.7	28.4	27.9	27.1	28.0	28.3	28.1	27.8	28.8	26.2	27.6	28.7	28.6	28.3

AUTORIZÓ:

Vo.Bo.

Edna Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx

Guillermo Nava Lujano
 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

glavde