



### PLANTA POTABILIZADORA PASTOR LOZANO

### ANALISIS FISICOQUÍMICOS AGUA CRUDA RIO BRAVO SEPTIEMBRE 2023

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	21.8	29.5	28.8	30.2	32.4	28.1	26.0	23.5	22.1	23.2	27.1	17.5	15.3	15.7	14.8	19.8	17.3	17.2	15.9	17.6	17.0	21.9
P.H.	7.7	8.08	8.1	7.9	7.6	7.8	7.9	8.0	8.2	7.7	7.8	7.7	7.9	7.8	7.7	7.9	7.6	7.7	7.7	7.7	7.7	7.8
ALCALINIDAD TOTAL	72	90	100	100	82	84	110	86	90	76	74	100	96	92	84	74	124	106	102	76	80	90
DUREZA TOTAL	340	296	296	312	310	336	310	320	282	284	286	264	268	264	280	288	298	288	292	266	260	292
DUREZA DE CALCIO	240	144	154	184	174	172	168	158	170	182	180	160	160	146	180	170	164	168	174	162	142	169
DUREZA DE MAGNESIO	100	152	142	128	136	164	142	162	112	102	106	104	108	118	100	118	134	120	118	104	118	123
CLORUROS	186	140	132	130	120	125	122	120	116	110	120	120	100	104	116	114	132	158	144	136	130	127
SDT	537	469	635	626	725	520	639	645	500	484	448	512	508	687	577	538	743	884	466	432	405	570
TEMPERATURA °C	26.8	25.3	26.4	26.1	27.7	27.5	28.2	28.6	29.0	27.8	29.8	27.7	27.7	27.7	27.8	27.8	28.7	27.6	28.4	28.1	27.9	27.7

AUTORIZÓ:

*Edna Marissa Soto Lozano*  
 I.Q. EDNA MARISSA SOTO LOZANO  
 JEFA DE LABORATORIO



Vb.Bo.

*Guillermo Nava Lujano*  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA

Río Pánuco S/N, esq. José de Escandón  
 Col. Longoria  
 Cd. Reynosa, Tamaulipas, México  
 www.comapareynosa.gob.mx