



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 SEPTIEMBRE 2023

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	58.0	44.7	38.7	38.0	37.5	42.5	38.1	43.5	44.9	45.6	43.5	51.2	30.1	25.4	24.1	38.2	42.9	28.1	30.1	31.2	31.9	38.5
P.H.	7.9	8.1	8.0	7.7	7.6	7.9	7.8	7.8	8.0	7.5	7.8	7.8	7.8	7.9	7.7	7.9	7.5	7.2	7.7	7.6	7.6	7.7
ALCALINIDAD TOTAL	74	94	80	90	78	86	96	90	78	74	70	96	84	80	72	82	100	88	90	74	90	84
DUREZA TOTAL	402	442	450	446	448	456	496	480	448	446	450	402	392	400	396	386	372	388	442	446	440	430
DUREZA DE CALCIO	266	216	246	240	252	264	222	224	216	210	232	192	180	208	224	224	192	212	212	216	218	222
DUREZA DE MAGNESIO	136	226	204	206	196	192	274	256	232	236	218	210	212	192	172	162	180	176	230	230	222	208
CLORUROS	266	250	272	264	268	276	280	272	266	266	288	258	236	272	264	278	274	258	280	292	290	270
SDT	844	801	1113	1117	1304	929	1215	1201	917	913	921	1001	980	1323	1045	1006	1289	1354	799	790	771	1030
TEMPERATURA °C	26.3	26.8	26.5	26.2	27.8	27.9	27.9	28.3	28.5	28.1	29.1	27.9	28.0	27.9	28.2	28.4	28.4	27.3	28.4	28.2	28	27.8

AUTORIZÓ:

Edna Marissa Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx



Vo.Bo.

Guillermo Nava Lujano
 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

Javiera