



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA RIO BRAVO
 OCTUBRE 2023**

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	PROMEDIO
TURBIEDAD N.T.U.	16.6	14.9	15.1	14.6	14.3	18.4	16.8	15.8	16.7	12.2	12.0	11.1	11.2	11.5	10.6	15.7	13.9	14.8	16.1	17.1	15.8	15.2	14.6
P.H.	7.7	7.8	7.6	7.8	7.9	8.0	7.9	7.7	7.4	7.8	7.8	7.4	7.8	7.8	7.6	7.6	7.7	7.6	7.7	7.7	7.6	7.7	7.7
ALCALINIDAD TOTAL	112	114	94	90	80	100	104	96	96	80	100	92	124	114	112	98	124	106	100	88	100	98	101
DUREZA TOTAL	248	280	266	284	264	270	262	276	284	294	260	274	294	260	270	268	320	326	310	300	312	286	282
DUREZA DE CALCIO	156	162	170	160	164	180	146	176	180	178	156	160	168	164	174	136	184	192	180	174	180	158	168
DUREZA DE MAGNESIO	92	118	96	124	100	90	116	100	104	116	104	114	126	96	96	132	136	134	130	126	132	128	114
CLORUROS	165	160	166	164	172	185	170	190	150	132	134	126	124	130	104	142	148	170	158	142	122	119	149
SDT	395	395	450	603	527	541	494	500	519	515	585	680	643	674	468	604	585	585	549	505	456	471	534
TEMPERATURA °C	28.9	28.5	28.5	28.8	26.6	23.9	24.8	24.2	25.4	26.1	24.9	23.0	22.4	23.7	24.4	26.0	26.1	26.4	26.0	26.5	22.8	20.4	25.4

AUTORIZÓ:

Edna Marissa Soto Lozano
 I.Q. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Vb.Bo.
Guillermo Nava Lujano
 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

