



PLANTA POTABILIZADORA PASTOR LOZANO


ANÁLISIS FÍSICOQUÍMICOS AGUA CRUDA RIO BRAVO NOVIEMBRE 2023

RESULTADOS EN MG/LT

FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	PROMEDIO
TURBIEDAD N.T.U.	15.2	16.8	17.2	14.8	13.1	13.5	14.0	14.1	16.4	18.0	16.3	15.9	16.7	13.1	13.2	14.6	14.9	14.0	14.4	17.0	13.3	12.0	14.9
P.H.	7.8	7.5	7.5	7.9	7.7	7.4	7.4	7.8	7.7	7.4	7.8	7.9	7.8	7.5	7.6	7.0	7.0	7.9	7.7	7.6	8.4	8.4	7.7
ALCALINIDAD TOTAL	84	120	118	130	104	100	104	102	110	108	110	108	108	104	106	106	108	102	92	94	122	128	108
DUREZA TOTAL	260	264	314	300	244	272	294	284	288	300	290	294	294	280	260	280	364	334	300	304	328	332	295
DUREZA DE CALCIO	146	146	128	170	128	156	154	176	186	172	180	180	178	180	170	180	170	188	200	214	218	220	175
DUREZA DE MAGNESIO	114	118	186	130	116	116	140	108	102	128	110	114	116	100	90	100	194	146	100	90	110	112	120
CLORUROS	126	114	124	110	110	118	122	128	118	124	114	120	126	124	120	120	124	130	128	140	192	228	130
SDT	499	518	640	655	640	439	579	513	511	510	503	530	605	536	530	430	423	489	442	467	580	615	530
TEMPERATURA °C	18.3	18.6	19.4	21.6	23.2	23.7	24.1	23.4	19.4	20.0	20.5	21.0	20.8	19.2	20.8	18.6	18.3	18.7	17.3	16.8	17.1	18.1	20.0

AUTORIZÓ:


 I.Q. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Vo.Bo.

 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA