



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 DICIEMBRE 2023**

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	26.9	29.8	29.4	29.2	25.6	27.6	29.2	34.8	41.5	31.9	31.3	35.9	37.5	38.5	27.0	39.4	24.9	36.5	28.9	27.9	32.0	31.7
P.H.	8.5	7.3	7.29	7.1	7.6	7.4	7.2	7.5	7.5	7.6	7.5	7.6	7.4	7.5	7.5	7.7	7.8	7.4	7.2	7.4	7.1	7.5
ALCALINIDAD TOTAL	78	86	84	80	80	88	80	82	104	96	96	92	88	100	98	112	136	148	126	134	134	101
DUREZA TOTAL	394	402	406	420	424	422	386	416	428	398	410	430	440	416	437	422	344	404	374	358	380	405
DUREZA DE CALCIO	200	206	222	244	274	264	254	232	236	240	220	246	234	246	236	226	154	226	234	210	230	230
DUREZA DE MAGNESIO	194	196	184	176	150	158	132	184	192	158	190	184	206	170	201	196	190	178	140	148	150	175
CLORUROS	284	260	280	262	280	264	242	262	276	282	230	250	270	250	258	260	153	163	248	222	192	247
SDT	1024	703	849	1135	846	1034	916	868	849	824	765	844	838	826	818	840	593	603	720	743	547	818
TEMPERATURA °C	19.4	17.9	19.6	20.0	20.0	20.5	18.5	18.8	19.2	19.6	19.7	18.0	17.7	18.3	19.2	20.0	19.7	17.7	17.7	16.9	16.9	18.8

AUTORIZÓ:

Vo.Bo.

Edna Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx

[Signature]
 BIÓLOGO GUILLERMO NAVA-LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

