



**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANÁLISIS FÍSICOQUÍMICOS  
 AGUA CRUDA CANAL RODHE  
 ENERO 2024**

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	36.5	30.8	26.5	36.6	27.6	39.8	45.7	56.6	32.7	36.2	28.6	44.5	26.7	23.6	20.9	28.5	25.8	19.3	17.5	14.9	23.3	22.0	26.6	30.1
P.H.	6.9	7.0	7.7	7.6	7.3	8.5	8.2	6.7	6.8	7.2	7.3	7.1	6.8	7.3	7.4	7.1	7.1	7.3	7.3	7.3	7.1	7.5	7.8	7.3
ALCALINIDAD TOTAL	144	138	148	134	134	158	148	156	140	136	136	126	134	138	136	132	146	124	140	146	128	132	134	139
DUREZA TOTAL	382	320	336	328	342	336	336	340	324	308	366	332	394	384	374	356	404	386	356	366	356	324	336	352
DUREZA DE CALCIO	220	200	200	184	196	200	184	160	162	210	220	230	232	234	268	220	300	266	264	214	192	150	188	213
DUREZA DE MAGNESIO	162	120	136	144	146	136	152	180	162	98	146	102	162	150	106	136	104	120	92	152	164	174	148	139
CLORUROS	207	196	188	214	218	222	224	220	194	172	148	132	140	140	144	142	146	140	160	148	152	148	150	172
SDT	576	502	495	604	685	625	792	781	782	884	548	513	520	549	519	535	606	567	553	525	529	682	579	607
TEMPERATURA °C	18.9	19.3	18.1	16.8	17.8	20.2	17.8	15.2	17.5	19.2	16.3	11.7	13.5	14.3	16.8	12.2	16.9	18.3	16.9	18.7	17.3	17.1	17.0	16.9

AUTORIZÓ:

*Edna Marissa Soto Lozano*  
 IQ. EDNA MARISSA SOTO LOZANO  
 JEFA DE LABORATORIO

vo.Bo.  
  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA