



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA POTABLE
 FEBRERO 2024**

RESULTADOS EN MG/LT

FECHA:	1	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	NOM-127/21	PROMEDIO
TURBIEDAD N.T.U.	4.0	3.8	4.0	4.0	4.0	3.6	3.4	4.0	3.7	4.0	4.0	3.8	3.9	3.6	4.0	3.9	3.8	3.8	3.7	3.8	3.4	4 NTU	3.8
P.H.	7.0	6.9	7.5	7.0	7.4	7.1	7.0	7.7	7.6	7.8	7.6	7.5	7.7	7.9	7.7	7.7	7.8	8.0	7.7	7.8	7.9	6,5-8,5	7.5
ALCALINIDAD TOTAL	110	118	122	124	120	124	118	114	120	120	126	122	140	138	132	130	138	120	126	122	126		124
DUREZA TOTAL	324	332	312	306	292	320	378	360	360	368	384	400	412	432	396	404	390	416	398	356	420	500 MG/LT	370
DUREZA DE CALCIO	202	200	190	180	182	186	198	184	162	204	216	206	220	210	216	206	200	236	220	210	200		201
DUREZA DE MAGNESIO	122	132	122	126	110	134	180	176	198	164	168	194	192	222	180	198	190	180	178	146	220		168
CLORUROS	152	176	180	180	194	206	196	172	165	175	185	172	160	180	160	161	170	160	182	160	160		174
CLORO RESIDUAL	0.9	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.3	1.5	1.5	1.5	1.5	1.5	1.5	0.9	1.5	0,2-1,5	1,4
SDT	680	878	853	733	645	635	651	591	613	618	614	574	563	610	611	614	623	628	632	631	642	1000 MG/LT	649
TEMPERATURA °C	19.1	20.5	19.1	18.1	18.9	20.3	21.5	19.9	19.1	19.1	20.6	19.5	16.7	17.9	19.7	20.9	22.2	21.9	23.2	23.9	19.7		20.1

AUTORIZÓ:

Edna Marissa Soto Lozano
 I.Q. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Río Pánuco S/N, esq. José de Escandón
 Col. Longoria
 Cd. Reynosa, Tamaulipas, México
 www.comapareynosa.gob.mx



Vo.Bo.

[Signature]
 BIODIEGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

*Recabi Original
 11-03-24
 [Signature]*