



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA RIO BRAVO
 MARZO 2024**

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	17.0	11.7	11.1	10.1	11.5	12.5	11.2	13.6	10.4	12.7	12.3	15.0	13.9	14.8	19.7	16.2	17.3	13.6	15.0	18.7	16.3	14.0
P.H.	7.5	6.7	7.4	7.7	7.6	7.9	7.4	7.5	7.4	7.5	7.5	7.6	7.0	7.5	7.7	7.9	7.5	7.7	7.8	7.9	7.9	7.5
ALCALINIDAD TOTAL	130	134	130	132	120	126	146	124	132	140	144	130	122	126	130	140	136	128	124	113	146	131
DUREZA TOTAL	426	392	366	330	382	364	362	354	386	382	322	420	314	342	292	301	273	261	280	284	330	341
DUREZA DE CALCIO	244	194	198	190	192	200	184	220	184	190	168	180	186	166	162	181	118	161	128	129	132	177
DUREZA DE MAGNESIO	182	198	168	140	190	164	178	134	202	192	154	240	128	176	130	120	155	100	152	155	198	165
CLORUROS	159	192	184	184	194	168	148	146	144	144	146	170	194	188	190	175	166	177	163	189	190	172
SDT	633	629	786	608	635	630	632	592	616	624	644	618	813	847	502	483	503	458	499	489	492	606
TEMPERATURA °C	18.0	22.3	22.4	23.4	24.3	24.7	20.3	21.6	22.8	24.5	24.4	23.2	21.0	20.7	21.3	22.0	24.0	23.4	22.7	22.5	21.9	22.4

AUTORIZÓ:

Edna Soto Loz
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Vo.Bo.

 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

Glenda de la Cruz