



PLANTA POTABILIZADORA PASTOR LOZANO

**ANÁLISIS FÍSICOQUÍMICOS
 AGUA CRUDA CANAL RODHE
 MARZO 2024**

RESULTADOS EN MG/LT

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	PROMEDIO
TURBIEDAD N.T.U.	41.0	31.5	21.2	38.9	20.5	19.6	41.2	57.0	14.4	17.1	21.5	46.5	35.1	20.2	15.9	24.0	16.2	35.0	26.5	24.9	26.4	28.3
P.H.	7.7	6.9	7.4	7.4	7.3	7.8	7.3	7.4	7.3	7.3	7.6	7.7	6.9	7.2	7.5	7.8	7.5	7.9	7.4	7.7	7.9	7.5
ALCALINIDAD TOTAL	140	136	134	130	130	116	148	146	136	134	136	166	154	130	136	142	156	148	128	126	130	138
DUREZA TOTAL	446	360	364	342	384	362	388	420	364	348	348	446	366	314	310	306	304	283	285	288	350	351
DUREZA DE CALCIO	206	240	192	204	194	192	244	206	196	220	162	240	212	206	210	165	196	173	171	136	124	195
DUREZA DE MAGNESIO	240	120	172	138	190	170	144	214	168	128	186	206	154	108	100	141	108	110	114	152	226	157
CLORUROS	183	176	186	188	188	188	188	200	192	206	202	195	238	222	216	219	195	207	215	195	195	200
SDT	694	595	744	610	669	674	735	714	729	730	759	778	989	924	550	543	560	513	564	506	510	671
TEMPERATURA °C	17.8	22.3	22.9	23.7	24.9	25.0	20.4	22.0	23.1	24.9	24.7	23.8	21.1	20.7	21.6	22.8	24.3	23.9	23.7	23.1	22.4	22.8

AUTORIZÓ:

Vo.Bo.

Edna Marissa Soto Lozano
 IQ. EDNA MARISSA SOTO LOZANO
 JEFA DE LABORATORIO

Guillermo Nava Lujano
 BIÓLOGO GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA

Glenda de la Cruz