


**PLANTA POTABILIZADORA PASTOR LOZANO**  
**ANALISIS FISICOQUÍMICOS**  
**AGUA CRUDA**  
**jun-17**

RESULTADOS EN MG/LT


FECHA:	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	10.1	5.8	8.6	8.4	7.9	10.1	9.6	8.6	10.5	16.8	14.2	19.7	15.2	13.6	13.9	13.0	16.5	11.6	10.6	12.5	5 NTU.	11.9
P.H.	7.8	7.8	7.9	7.8	7.7	8.1	7.7	8.0	7.8	7.7	8.0	7.9	7.9	7.9	7.9	7.9	7.8	7.8	7.8	7.7	6.5-8.5	7.9
ALCALINIDAD TOTAL	120	100	124	130	144	110	120	104	110	114	118	112	102	1106	130	120	102	110	106	110		164.6
DUREZA TOTAL	220	280	292	388	334	344	296	282	310	278	280	270	270	260	254	246	234	202	248	270	500 MG/LT	277.9
CLORUROS	175	200	220	215	230	200	165	185	188	173	168	154	170	162	180	172.5	265	177	187	184	250 MG/LT	188.5
CLORO RESIDUAL																						
CALCIO	130	58	168	196	144	180	174	50	92	78	100	112	112	94	98	170	185	86	104	108		122.0
MAGNESIO	90	222	124	192	190	164	122	232	218	200	180	158	158	166	156	76	49	116	144	162		156.0
SDT	502.5	512.5	518	587	615	670	565	517	497	482.5	454.5	456.5	447.5	449.5	446	457.5	465	457	447	455	1000 MG/LT	500.0

Realizó



CFB. MIRIAM CÁVAZOS GARCIA  
JEFE DE LABORATORIO

Vo. Bo.



BIOD. JUAN GUILLERMO NAVA LUIANO  
COORDINADOR DE CALIDAD DEL AGUA