



• REYNOSA
• TAMAUlipas
• GOBIERNO DEL ESTADO

• COMAPA
• REYNOSA
Comisión Municipal de Agua Potable y
Abastecimiento del Municipio de Reynosa



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS AGUA POTABLE ENERO 2015

| RESULTADOS EN MG/LT | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---------------------|-----|------|------|-----|-----|-----|-----|------|-----|-----|------|-------|------|-----|-------|-----|------|------|------|------|------|---------------|----------|--|--|--|--|--|--|--|--|--|--|
| FECHA: | 2 | 5 | 6 | 7 | 8 | 9 | 12 | 13 | 14 | 15 | 16 | 19 | 20 | 21 | 22 | 23 | 26 | 27 | 28 | 29 | 30 | NOM-127/84 | PROMEDIO | | | | | | | | | | |
| TURBIEDAD N.T.U. | 4.8 | 5.0 | 5.0 | 4.9 | 5.0 | 4.9 | 4.7 | 4.1 | 4.7 | 4.2 | 3.4 | 4.2 | 5 | 5 | 4.7 | 5.4 | 4 | 5 | 5 | 5 | 5.5 | 5 NTU. | 4.7 | | | | | | | | | | |
| P.H. | 7.4 | 7.6 | 7.6 | 7.5 | 7.5 | 7.5 | 7.7 | 7.5 | 7.5 | 7.6 | 7.5 | 7.6 | 7.5 | 7.6 | 7.5 | 7.7 | 7.6 | 7.7 | 7.5 | 7.5 | 7.6 | 6.5-8.5 | 7.6 | | | | | | | | | | |
| ALCALINIDAD TOTAL | 108 | 114 | 118 | 130 | 140 | 110 | 120 | 140 | 148 | 160 | 144 | 140 | 146 | 142 | 148 | 152 | 146 | 145 | 160 | 160 | 146 | | 138.9 | | | | | | | | | | |
| DUREZA TOTAL | 370 | 390 | 398 | 390 | 390 | 380 | 398 | 410 | 430 | 460 | 460 | 446 | 460 | 490 | 480 | 445 | 480 | 442 | 470 | 460 | 470 | 500 MG/LT | 434.2 | | | | | | | | | | |
| CLORUROS | 220 | 22 | 210 | 218 | 220 | 220 | 258 | 250 | 275 | 285 | 306 | 285 | 2785 | 290 | 278 | 284 | 290 | 270 | 310 | 320 | 301 | 250 MG/LT | 376.0 | | | | | | | | | | |
| CLORO RESIDUAL | 14 | 1.36 | 0.84 | 1.3 | 1.1 | 1.2 | 1.2 | 1.17 | 1.4 | 1.5 | 1.37 | 1.3 | 1.06 | 1.5 | 0.97 | 0.9 | 0.87 | 1 | 1.3 | 0.65 | 1.36 | 0.2-1.5 MG/LT | 1.8 | | | | | | | | | | |
| CALCIO | 210 | 250 | 236 | 218 | 220 | 250 | 248 | 250 | 268 | 270 | 260 | 250 | 270 | 266 | 290 | 298 | 284 | 330 | 310 | 300 | 302 | | 265.7 | | | | | | | | | | |
| MAGNESIO | 160 | 140 | 162 | 172 | 170 | 130 | 150 | 160 | 162 | 190 | 200 | 196 | 190 | 224 | 190 | 147 | 196 | 112 | 160 | 160 | 168 | | 168.5 | | | | | | | | | | |
| SDT | 655 | 757 | 781 | 783 | 753 | 794 | 918 | 923 | 936 | 965 | 1000 | 891.5 | 934 | 934 | 931.5 | 920 | 1030 | 1030 | 1035 | 1000 | 928 | 1000 MG/LT | 900.0 | | | | | | | | | | |

C.E.E. MIRIAM CAVANOS GARCIA
ENCARGADA DE LABORATORIO.

Vo.Bo.

BIOLOGO GUILLERMO AVILA LUJANO
COORDINADOR DE CALIDAD DEL AGUA