



● **REYNOSA**  
● **TAMAULIPAS**  
GOBIERNO DEL ESTADO


● **COMAPA**  
REYNOSA  
Comisión Municipal de Agua Potable y  
Alcantarillado del Municipio de Reynosa




**PLANTA POTABILIZADORA PASTOR LOZANO**

**ANALISIS FISICOQUIMICOS  
AGUA CRUDA  
ENERO 2015**

FECHA:	2	5	6	7	8	9	12	13	14	15	16	19	20	21	22	23	26	27	28	29	30	NOM-127/94	PROMEDIO	
TURBIEDAD N.T.U.	13.2	23.4	13.8	13.1	21.8	17.1	12.8	18.0	17.1	13.4	13.2	10.1	11.9	16.9	11.3	15.6	15.6	8.3	8.3	9.6	10.8		5 NTU.	14.1
P.H.	7.7	7.5	7.6	7.8	7.7	7.7	7.9	7.8	7.6	7.6	7.6	7.9	8	7.6	7.8	8	7.7	8	8	8	7.6		6.5-8.5	7.8
ALCALINIDAD TOTAL	112	126	124	136	130	130	130	150	150	156	156	150	150	148	158	160	150	166	170	170	158			146.7
DUREZA TOTAL	368	380	390	398	396	370	390	408	420	440	448	480	480	486	440	435	486	458	480	480	470		500 MG/LT	433.5
CLORUROS	210	205	205	210	210	215	248	248	270	275	300	280	260	280	288	278	280	262	300	315	301		250 MG/LT	289.0
CALCIO	198	230	230	216	240	240	260	260	260	250	260	260	280	270	286	290	280	330	300	280	302			263.4
MAGNESIO	170	150	160	182	156	130	130	148	160	190	188	220	200	216	154	145	206	128	180	190	168			170.0
SDT	680	764	795	791	755	808	916	918	944	975	1005	889	935	962	933	944	1035	1020	1030	993	928		1000 MG/LT	805.7

  
OFE MIRIAM CAVAZOS GARGA  
ENCARGADA DE LABORATORIO.

  
BILOGO GUZTERMO NAVAJOTIANO  
COORDINADOR DE CALIDAD DEL AGUA