

PLANTA POTABILIZADORA PASTOR LOZANO



COMAPA
COMISIÓN MUNICIPAL DE AGUA POTABLE Y
ALDANTARILLADO DEL MUNICIPIO DE REYNOSA
REYNOSA IMPARABLE

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
OCTUBRE 2024

RESULTADOS EN MG/LT

FECHA:	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	NOM-127/21	PROMEDIO
TURBIEDAD N.T.U.	4.0	3.6	3.0	3.4	4.0	4.0	3.5	3.8	3.4	3.0	3.2	3.4	3.5	3.6	3.8	4.0	3.9	4.0	3.9	3.6	3.9	4.0	4 NTU	3.7
P.H.	7.0	6.8	7.2	7.3	7.5	7.3	7.3	6.8	7.4	6.8	7.1	7.4	7.1	7.2	7.2	7.5	7.2	7.2	6.8	6.8	7.2	6.9	6.5-8.5	7.1
ALCALINIDAD TOTAL	76	83	90	82	80	73	81	87	94	79	91	78	92	90	92	80	98	94	96	98	92	88		87
DUREZA TOTAL	256	269	270	252	266	269	279	288	267	270	269	274	280	278	288	267	283	288	290	264	271	270	500 MG/LT	273
DUREZA DE CALCIO	160	162	174	160	178	166	173	180	172	172	165	179	175	170	182	161	175	180	176	170	182	172		172
DUREZA DE MAGNESIO	96	107	96	92	88	103	106	108	95	98	104	95	105	108	106	106	108	108	114	94	89	98		101
CLORUROS	157	154	165	158	152	154	162	155	178	150	163	165	160	161	167	180	158	152	156	142	150	150		158
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	524	530	545	555	563	562	567	547	538	520	512	501	498	500	530	556	546	530	499	489	482	476	1000 MG/LT	526
TEMPERATURA °C	20.8	25.1	24.5	23.0	22.6	23.8	25.0	26.0	24.1	23.7	22.7	22.6	23.7	24.1	23.2	24.2	22.9	24.8	25.4	25.1	24.8	23.2		23.9

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo.Bo.
BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

7/Endu