

PLANTA POTABILIZADORA PASTOR LOZANO



COMAPA
COMISIÓN MUNICIPAL DE AGUA POTABLE Y
ALCANTARILLADO DEL MUNICIPIO DE REYNOSA
REYNOSA IMPARABLE

ANÁLISIS FÍSICOQUÍMICOS AGUA CRUDA CANAL RODHE OCTUBRE 2024

RESULTADOS EN MG/LT

FECHA:	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	PROMEDIO
TURBIEDAD N.T.U.	20.4	18.2	19.3	22.5	15.8	20.2	19.4	23.1	18.9	16.2	27.9	20.2	20.3	19.9	25.4	12.3	26.4	25.1	24.1	26.5	21.6	23.3	21.2
P.H.	7.0	7.5	7.8	7.5	7.8	8.0	8.0	7.6	7.8	7.6	7.6	8.0	7.1	7.5	7.6	7.8	7.5	7.2	7.0	7.9	7.9	7.3	7.6
ALCALINIDAD TOTAL	90	95	85	99	88	80	86	85	98	92	94	86	91	99	100	90	102	88	106	97	92	85	92
DUREZA TOTAL	273	278	283	290	268	270	282	289	275	277	279	286	281	297	284	268	286	290	276	279	283	278	281
DUREZA DE CALCIO	170	169	179	180	168	160	172	180	170	174	168	182	179	191	182	164	180	173	160	169	180	170	174
DUREZA DE MAGNESIO	103	107	104	110	100	110	110	109	105	103	111	104	102	106	102	104	108	117	116	110	103	108	107
CLORUROS	164	156	159	154	150	154	156	158	164	155	174	168	175	171	158	161	164	156	157	140	145	146	158
SDT	552	569	560	568	573	574	576	551	527	535	530	533	520	540	568	578	567	557	520	518	487	474	544
TEMPERATURA °C	21.3	24.7	23.2	23.2	22.9	23.7	24.5	25.2	24.0	23.5	23.0	23.0	23.3	23.8	23.7	23.9	23.8	24.5	25.0	24.9	24.9	22.8	23.8

AUTORIZO:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA