



PLANTA POTABILIZADORA PASTOR LOZANO



ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
DICIEMBRE 2024

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	26	27	30	31	NOM-127/21	PROMEDIO
TURBIEDAD N.T.U.	4.0	3.8	3.9	3.8	4.0	4.0	3.6	3.6	3.8	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	3.9	4.0	3.8	3.9	4 NTU	3.9
P.H.	7.3	7.3	7.4	7.4	7.3	7.4	7.4	7.3	7.2	7.2	7.3	7.4	7.3	7.4	7.4	7.2	7.3	7.3	7.3	7.4	7.4	6,5-8,5	7.3
ALCALINIDAD TOTAL	100	108	100	112	111	110	118	110	108	103	104	109	102	110	114	114	110	106	102	108	110		108
DUREZA TOTAL	262	267	273	265	286	261	263	266	280	292	290	297	295	290	288	292	295	280	278	282	290	500 MG/LT	281
DUREZA DE CALCIO	160	166	170	165	177	160	150	165	171	175	172	177	176	172	170	169	176	174	172	170	173		170
DUREZA DE MAGNESIO	102	101	103	100	109	101	113	101	109	117	118	120	119	118	118	123	119	106	106	112	117		101
CLORUROS	149	141	146	151	159	147	140	155	142	149	156	152	160	150	145	148	152	158	144	150	148		150
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	560	555	548	540	538	530	552	543	534	525	524	535	551	554	569	564	569	560	552	548	532	1000 MG/LT	547
TEMPERATURA °C	21.1	20.7	20.3	20.9	21.1	20.5	20.9	20.2	20.4	20.7	21.4	22.3	22.0	22.2	22.1	21.7	22.0	23.3	22.8	22.2	22.5		21.5

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA



o S/N, esq. José de Escandón
ria
3a, Tamaulipas, México
pareynosa.gob.mx

