



● REYNOSA
● TAMAUULIPAS
● GOBIERNO DEL ESTADO DE TAMAUULIPAS

● COMAPA
● REYNOSA
Comisión Municipal de Agua Potable y
Alcantarillado del Municipio de Reynosa



TODOS POR
TAMAUULIPAS

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA POTABLE
ENERO 2016

| FECHA: | 4 | 5 | 6 | 7 | 8 | 11 | 12 | 13 | 14 | 15 | 18 | 19 | 20 | 21 | 22 | 25 | 26 | 27 | 28 | 29 | NOM127/94 | PROMEDIO |
|-------------------|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|------|------|-----|-----|-----|-----|-----|-----|-----|-----|---------------|----------|
| TURBIEDAD N.T.U. | 2.4 | 2.4 | 3.5 | 3.1 | 3.6 | 3.9 | 5.0 | 5.0 | 5.0 | 5.0 | 4.6 | 5.0 | 5.0 | 4.6 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 4.9 | 5 NTU. | 4.4 |
| P.H. | 7.5 | 7.4 | 7.4 | 7.5 | 7.6 | 7.7 | 7.5 | 7.4 | 7.4 | 7.4 | 7.4 | 7.5 | 7.4 | 7.5 | 7.5 | 7.4 | 7.5 | 7.5 | 7.4 | 7.6 | 6.5-8.5 | 7.5 |
| ALCALINIDAD TOTAL | 120 | 128 | 114 | 124 | 130 | 144 | 144 | 140 | 132 | 166 | 190 | 152 | 150 | 143 | 140 | 156 | 150 | 150 | 148 | 140 | | 143.1 |
| DUREZA TOTAL | 362 | 370 | 430 | 436 | 396 | 398 | 490 | 422 | 438 | 450 | 440 | 478 | 450 | 446 | 470 | 406 | 420 | 480 | 460 | 424 | 500 MG/LT | 433.3 |
| CLORURROS | 190 | 198 | 200 | 250 | 250 | 250 | 248 | 250 | 250 | 248 | 250 | 250 | 250 | 248 | 250 | 250 | 250 | 248 | 250 | 250 | 250 MG/LT | 241.5 |
| COLORO RESIDUAL | 1.5 | 1.4 | 1.5 | 1.5 | 1.5 | 1.2 | 1.5 | 1.5 | 1.4 | 1.5 | 1.5 | 1.4 | 1.5 | 1.5 | 1.4 | 1.5 | 1.5 | 1.3 | 1.5 | 1.5 | 0.2-1.5 MG/LT | 1.5 |
| CALCIO | 212 | 196 | 240 | 204 | 250 | 280 | 286 | 278 | 240 | 280 | 310 | 300 | 310 | 248 | 288 | 220 | 268 | 260 | 304 | 280 | | 260.7 |
| MAGNESIO | 150 | 174 | 190 | 232 | 146 | 138 | 204 | 144 | 198 | 170 | 130 | 178 | 140 | 198 | 202 | 186 | 152 | 220 | 156 | 144 | | 172.6 |
| SDT | 635 | 671 | 686 | 743 | 758 | 926 | 1020 | 945 | 819 | 902 | 1020 | 1045 | 918 | 838 | 846 | 902 | 870 | 882 | 912 | 841 | 1000 MG/LT | 859.0 |

QFB. MIRIAM CAVAZOS GARZA
JEFF DE LABORATORIO.

Vo.Bo.

BILOLO GUILLEMO NAVA TUJANO
COORDINADOR DE CALIDAD DEL AGUA