



PLANTA POTABILIZADORA PASTOR LOZANO



COMAPA
COMISIÓN MUNICIPAL DE AGUA POTABLE Y
ALOANTARILLADO DEL MUNICIPIO DE REYNOSA
REYNOSA, TAMPAULIPAS

ANÁLISIS FÍSICOQUÍMICOS AGUA CRUDA RIO BRAVO DICIEMBRE 2024

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	26	27	30	31	PROMEDIO
TURBIEDAD N.T.U.	18.7	17.6	19.2	20.2	20.9	19.4	18.7	24.4	27.0	25.3	20.7	18.7	19.5	18.2	18.5	19.3	18.4	20.0	18.3	19.7	19.6	20.1
P.H.	7.2	7.2	7.3	7.1	7.3	7.2	7.3	7.6	7.3	7.5	7.4	7.6	7.7	7.5	7.4	7.5	7.9	7.6	7.7	7.3	7.3	7.4
ALCALINIDAD TOTAL	109	112	106	100	103	107	102	111	108	110	108	116	118	119	118	114	110	112	117	115	119	111
DUREZA TOTAL	262	270	279	266	272	259	261	258	270	275	280	289	300	314	318	311	310	322	316	320	330	290
DUREZA DE CALCIO	162	170	175	162	166	159	158	155	166	168	173	178	180	188	190	188	192	210	208	210	210	179
DUREZA DE MAGNESIO	100	100	104	104	106	100	103	103	104	107	107	111	120	126	128	123	118	112	108	110	120	105
CLORUROS	140	147	150	145	145	140	148	140	155	143	151	150	161	168	170	168	175	166	170	168	160	155
SDT	526	528	530	532	526	520	532	543	524	520	528	539	553	555	572	570	573	566	570	580	581	546
TEMPERATURA °C	21.2	20.9	19.4	20.3	20.6	19.8	20.7	19.6	19.7	19.8	21.3	21.8	21.1	20.2	21.2	21.2	20.8	20.3	20.0	21.0	21.0	20.6

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA



ánuco S/N, esq. José de Escandón
ongoria
eynosa, Tamaulipas, México
omapareynosa.gob.mx

