



REYNOSA
TAMAULIPAS
ESTADO DE TAMAULIPAS

COMAPA
REYNOSA
Comisión Municipal de Agua Potable y
Asesoría Técnica del Municipio de Reynosa



TODOS POR
TAMAULIPAS

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS AGUA CRUDA ENERO 2016

FECHA:	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	12.9	8.5	10.9	11.7	10.7	11.9	12.2	9.7	11.4	8.1	7.0	7.3	8.4	8.2	9.0	8.9	8.1	10.1	12.3	8.3	5 NTU.	9.8
P.H.	7.7	7.8	7.7	7.7	7.6	7.7	7.6	7.8	7.9	7.7	7.7	7.8	7.7	7.7	7.6	7.8	7.7	7.8	7.7	7.7	6.5-8.5	7.7
ALCALINIDAD TOTAL	130	132	116	116	136	164	148	143	148	164	166	158	152	150	148	152	160	154	152	140		146.5
DUREZA TOTAL	370	380	420	428	408	396	400	410	430	440	420	488	490	448	460	460	470	460	480	424	500 MG/LT	434.1
CLORUROS	195	193	190	260	248	250	248	250	250	247	250	248	250	240	250	248	250	246	250	244	250 MG/LT	239.9
CALCIO	214	190	230	200	210	300	310	290	260	270	300	336	282	200	260	260	272	250	276	280		259.5
MAGNESIO	156	190	190	228	198	96	90	120	170	170	120	152	208	248	200	200	198	210	204	144		174.6
SDT	39	662	705	686	753	966	1025	929	930	898	1015	1025	885	797	857	897	853	894	893	806	1000 MG/LT	825.8

D.F.B. MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO.

Va. Bc.
BIOLOGO CUILEBMO TNAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA