


PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA POTABLE
FEBRERO 2016

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.9	5.0	5.0	4.8	5.0	5.0	4.9	5.0	4.8	5.0	4.9	5.0	4.2	5.0	4.1	4.4	4.9	5.0	5.0	5.0	5 NTU.	4.8
P.H.	7.6	7.4	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.6	7.5	7.5	7.6	7.5	7.4	7.4	7.4	7.3	7.4	7.4	6.5-8.5	7.5
ALCALINIDAD TOTAL	136	120	150	132	138	112	98	98	94	98	88	100	102	104	94	92	92	94	90	84		105.8
DUREZA TOTAL	426	364	390	396	346	340	358	338	354	348	350	333	332	328	340	322	338	350	340	340	500 MG/LT	351.7
CLORURROS	260	193	202	192	163	168	178	185	170	187	171	166	160	164	165	150	135	153	158	143	250 MG/LT	172.7
CLORO RESIDUAL	1.5	1.4	1.5	1.5	1.5	1.4	1.5	1.5	1.5	1.4	1.5	1.4	1.4	1.3	1.5	1.4	1.5	1.5	1.4	1.5	0.2-1.5 MG/LT	1.5
CALCIO	280	248	240	260	220	220	280	208	232	194	190	228	332	150	200	170	160	176	176	180		217.2
MAGNESIO	146	116	150	136	126	120	78	130	122	154	160	105	0	178	140	152	178	174	164	160		134.5
SDT	735	683.5	700	700	645	667.5	645	641.5	625	645	595	602.5	580	535	586	542	552.5	582	591	555	1000 MG/LT	620.4


QFB MIRIAM CAVAZOS GARCÓN
JEFE DE LABORATORIO.


BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA