



• REYNOSA
• TAMAUULIPAS
• GOBIERNO DEL ESTADO

• COMAPA
REYNOSA
Comisión Municipal de Agua Potable y
Aseo Urbano del Municipio de Reynosa



TODOS POR
TAMAUULIPAS

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
FEBRERO 2016

FECHA:	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	13.6	14.8	11.5	11.6	10.9	9.6	13.3	10.9	12.0	11.7	14.7	12.0	13.4	15.8	11.2	15.4	16.3	15.0	15.3	17.1	5 NTU.	13.3
P.H.	7.8	7.8	7.6	7.7	7.8	7.7	7.8	7.7	7.8	7.8	7.9	7.8	7.8	7.8	7.6	7.6	7.9	7.7	7.6	7.6	6.5-8.5	7.7
ALCALINIDAD TOTAL	140	146	140	130	130	118	110	102	96	100	100	90	92	96	92	90	82	94	92	84		106.2
DUREZA TOTAL	286	260	220	220	280	396	382	330	346	314	330	342	340	302	308	302	290	340	346	336	500 MG/LT	312.5
CLORUROS	250	172	210	190	161	174	170	180	174	176	166	151	155	150	134	140	140	140	160	122	250 MG/LT	165.8
CALCIO	180	160	140	150	180	224	230	222	210	212	160	212	204	196	188	148	180	180	180	194		187.5
MAGNESIO	106	100	80	70	80	172	152	108	136	102	170	130	136	106	120	154	110	160	166	142		125.0
SDT	735	704	735	700.5	645	678	670	635	635	649	600	590	560	565	587	537.5	551	581	597	556.5	1000 MG/LT	625.6

DEB MIRIAM CAVAZOS GARCIA
JEFE DE LABORATORIO.

BIÓLOGO GUILLERMINO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

Vo Bo