

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
JULIO 2025

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	NOM-127/21	PROMEDIO
TURBIDEZ NTU	3.8	4.0	3.9	4.0	3.9	4.0	4.0	3.8	3.7	3.8	3.7	3.7	3.8	4.0	3.9	4.0	3.9	3.8	3.9	3.8	4.0	3.9	3.8	4 NTU	3.9
P.H.	7.3	7.3	7.3	7.4	7.3	7.4	7.3	7.3	7.5	7.0	7.5	7.0	7.0	7.1	7.2	7.1	7.4	7.2	7.2	7.2	7.4	7.3	7.5	6,5-8,5	7.3
ALCALINIDAD TOTAL	80	88	93	90	88	95	90	90	96	90	88	94	92	95	92	98	87	94	85	95	92	86	86		91
DUREZA TOTAL	329	314	314	317	317	323	349	375	351	330	343	349	361	372	342	336	331	333	336	328	314	315	305	500 MG/LT	334
DUREZA DE CALCIO	200	191	188	190	180	199	206	210	231	192	217	224	240	239	208	205	192	188	178	166	160	185	180		199
DUREZA DE MAGNESIO	129	123	126	127	137	124	143	165	120	138	126	125	121	133	134	131	139	145	158	162	154	130	125		130
CLORUROS	215	210	209	212	212	222	222	222	228	225	230	227	230	237	240	239	225	220	225	223	221	212	210		222
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	725	730	731	733	728	736	742	749	754	766	781	786	773	771	798	770	768	750	742	730	738	740	746	1000 MG/LT	752
TEMPERATURA °C	25.9	25.0	24.8	25.4	27.8	27.2	27.2	26.0	26.8	27.2	28.0	26.8	26.9	27.2	26.8	25.9	26.8	27.5	27.0	27.2	26.7	27.4	25.9		26.7

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

V.O.B.

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

S/N, esq. José de Escandón
ia
a, Tamaulipas, México
areynosa.gob.mx

