

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
AGOSTO 2025

RESULTADOS EN MG/LT

PARAMETRO	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/21	PROMEDIO
TURBIDEIDAD NTU	4.0	3.8	4.0	3.8	3.6	4.0	3.8	4.0	3.6	4.0	4.0	3.9	3.8	4.0	3.8	4.0	4.0	3.9	3.5	3.9	4.0	4 NTU	3.9
pH	7.5	7.0	7.1	7.2	7.2	7.2	7.5	7.4	7.2	7.0	7.3	7.2	7.1	7.4	7.2	7.2	7.5	7.2	7.4	7.4	7.2	6.5-8.5	7.3
ALCALINIDAD TOTAL	84	94	102	100	98	96	89	91	92	101	95	95	94	89	90	88	90	90	85	82	85		92
DUREZA TOTAL	296	275	280	277	282	288	286	277	262	259	277	262	267	264	257	258	262	276	274	260	280	500 MG/LT	272
DUREZA DE CALCIO	166	155	165	177	185	176	170	171	165	158	165	152	160	163	152	152	158	167	160	150	166		163
DUREZA DE MAGNESIO	130	120	115	100	97	112	116	106	97	101	112	110	107	101	105	106	104	109	114	110	114		95
CLORURO	198	181	191	188	190	198	178	161	166	150	153	157	164	161	155	156	156	157	169	170	179		170
OLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDA	560	569	583	570	582	595	581	580	562	560	555	542	533	525	529	539	547	554	566	558	569	1000 MG/LT	560
TEMPERATURA (°C)	26.1	28.8	28.6	25.7	26.7	27.4	27.4	29.0	29.7	28.9	28.7	28.8	28.8	28.5	28.0	28.2	27.4	27.6	26.7	27.9	28.2		28.0

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo.Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

