

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
SEPTIEMBRE 2025

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	17	18	19	22	23	24	25	26	29	30	NOM-127/21	PROMEDIO
TURBIDEIDAD NTU	4.0	3.8	3.9	3.5	4.0	3.9	4.0	3.8	4.0	3.8	4.0	3.7	4.0	3.8	4.0	3.9	3.8	4.0	3.9	4.0	3.9	4 NTU	3.9
pH	7.3	7.2	7.4	7.3	7.5	7.4	7.4	7.3	7.1	7.4	7.6	7.3	7.1	7.4	7.4	7.4	7.5	7.5	7.5	7.0	7.2	6.5-8.5	7.3
ALCALINIDAD TOTAL	84	85	84	85	81	91	89	85	85	85	90	85	82	85	84	88	99	94	93	85	90		87
DUREZA TOTAL	260	247	260	274	267	286	289	281	275	275	276	283	270	260	263	280	286	277	270	262	277	500 MG/LT	272
DUREZA DE CALCIO	142	139	148	150	150	165	170	166	165	152	160	158	150	148	150	166	167	163	150	149	150		155
DUREZA DE MAGNESIO	118	108	112	124	117	121	119	115	110	123	116	125	120	112	113	114	119	114	120	113	127		103
CLORUROS	172	165	155	165	155	163	174	170	170	170	176	168	176	160	165	173	175	178	164	165	172		168
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5	1.5
SDT	532	548	550	563	547	532	520	528	532	540	438	523	518	517	523	530	527	517	515	518	507	1000 MG/LT	525
TEMPERATURA °C	28.9	29.0	26.8	28.3	28.7	27.1	27.0	27.5	26.2	28.0	28.2	27.2	26.7	26.7	27.3	28.0	26.5	26.5	26.5	24.6	25.7		27.2

AUTORIZÓ:

IQ. ANDREA RODRÍGUEZ AGUILAR
ANALISTA DE LABORATORIO

Vo-Bo.

BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

