



PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA CANAL RODHE
SEPTIEMBRE 2025



COMAPA
COMISIÓN MUNICIPAL DE AGUA POTABLE Y
ALCANTARILLADO DEL MUNICIPIO DE REYNOSA
REYNOSA IMPARABLE

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	17	18	19	22	23	24	25	26	29	30	PROMEDIO
TURBIDEZ NTU	31.8	21.6	34.3	22.3	28.1	26.0	19.4	15.3	29.3	22.1	20.8	18.5	20.6	20.3	26.3	22.5	30.0	30.0	23.1	21.0	34.1	24.6
pH	7.5	7.3	7.4	7.5	7.4	7.5	7.9	7.4	7.6	7.5	7.4	7.4	7.1	7.7	7.6	7.7	7.4	7.4	7.5	7.1	7.3	7.5
ALCALINIDAD TOTAL	93	93	99	85	86	95	90	98	100	95	95	96	90	98	94	96	100	95	100	93	95	95
DUREZA TOTAL	264	272	260	277	270	263	278	270	287	270	277	287	265	262	276	289	291	290	292	268	280	276
DUREZA DE CALCIO	140	151	144	159	145	138	148	150	163	145	159	162	142	140	155	165	174	165	177	153	149	154
DUREZA DE MAGNESIO	124	121	116	118	125	125	130	120	124	125	118	125	123	122	121	124	117	125	115	115	131	111
CLORUROS	178	178	166	172	170	150	156	150	176	165	165	160	160	150	166	180	179	180	177	167	165	167
SOT	545	530	542	540	535	548	555	566	572	570	565	560	562	550	526	528	520	518	525	520	530	543
TEMPERATURA OC	28.5	28.5	26.5	27.8	28.7	27.0	27.0	26.3	25.6	22.1	27.5	26.5	26.4	26.1	27.5	27.8	26.8	26.8	26.1	24.5	25.5	26.6

AUTORIZÓ:

IQ. ANDREA RODRIGUEZ AGUILAR
ANALISTA DE LABORATORIO

Ver.Bo.

BIOLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA