

PLANTA POTABILIZADORA PASTOR LOZANO  
ANÁLISIS FÍSICOQUÍMICOS  
AGUA POTABLE  
MARZO 2016

RESULTADOS EN MG/LT

FECHA:	1	2	4	7	8	9	10	11	14	15	16	17	18	22	23	28	29	30	31	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.5	4.3	5.0	5.0	5.0	4.7	2.5	2.0	3.3	3.2	3.6	4.9	5.0	4.8	5.0	2.4	3.3	3.7	3.2	5 NTU.	4.0
P.H.	7.4	7.4	7.4	7.5	7.5	7.5	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.4	7.5	7.4	7.4	7.5	6.5-8.5	7.4
ALCALINIDAD TOTAL	88	86	82	80	78	76	90	80	80	72	78	76	86	92	80	100	102	94	102		85.4
DUREZA TOTAL	348	350	332	294	308	310	332	304	308	308	314	316	340	328	308	404	372	306	362	500 MG/LT	328.6
CLORUROS	161	164	165	129	153	152	155	138	137	143	141	143	157	140	151	178	168	145	162	250 MG/LT	151.7
CLORO RESIDUAL	1.5	1.5	1.2	1.3	1.3	1.5	1.5	1.5	1.5	1.5	1.2	1.3	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5 MG/LT	1.4
CALCIO	188	188	186	174	142	140	186	180	182	178	158	160	200	210	206	258	232	174	200		186.4
MAGNESIO	160	162	146	120	166	170	146	124	126	130	156	156	140	118	102	146	140	132	162		142.2
SDT	579	545	521.5	548.5	556.5	556	557.5	537.5	525	530	505	549	556.5	589.5	590	497	566	531	519	1000 MG/LT	545.2

  
JFB MIRIAM CAVAZOS GARCÍA  
JEFE DEL LABORATORIO.

  
Vo.Bo.  
BIÓLOGO GUILLERMO NAVAJUANO  
COORDINADOR DE CALIDAD DEL AGUA