

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA POTABLE
MARZO 2015

RESULTADOS EN MG/LT

FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	4.1	2.7	4.3	3.2	3.2	3.5	5.0	3.4	3.8	2.2	3.1	2.3	2.4	3.1	2.9	3.4	2.8	2.7	2.2	3.6	3.5	5 NTU.	3.2
P.H.	7.7	7.6	7.6	7.6	7.6	7.7	7.6	7.7	7.5	7.7	7.5	7.5	7.7	7.5	7.6	7.8	7.5	7.7	7.7	7.7	7.7	6.5-8.5	7.6
ALCALINIDAD TOTAL	116	120	124	132	136	124	118	130	136	152	120	128	134	146	140	140	140	144	142	130	136		132.8
DUREZA TOTAL	406	380	370	410	390	390	360	386	380	360	390	364	388	398	390	376	390	422	370	414	420	500 MG/LT	387.8
CLORUROS	175	165	190	186	176	182	189	177	180	182	185	120	183	195	210	218	210	218	219	206	215	250 MG/LT	189.6
CLORO RESIDUAL	1.0	1.0	1.0	1.2	1.3	1.0	1.1	1.2	1.2	1.2	1.0	1.5	1.3	1.3	1.0	1.5	1.2	1.3	1.1	1.1	1.2	0.2-1.5 MG/LT	1.2
CALCIO	248	240	232	214	220	230	220	210	220	240	222	220	226	220	230	250	226	252	266	260	280		234.6
MAGNESIO	158	140	138	196	170	160	140	177	160	120	156	144	162	178	160	126	164	170	104	154	140		153.3
SDT	658	684	673	662	692	681	678	682	683	674	665	666	668	665	705	726	740	729	728	736	740	1000 MG/LT	692.1


C.R.B. MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO


Vo.Bo.
BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA