

**PLANTA POTABILIZADORA PASTOR LOZANO**  
**ANALISIS FISICOQUÍMICOS**  
**AGUA CRUDA**  
**jul-17**

RESULTADOS EN MG/LT


FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	11.0	11.4	12.7	16.1	15.4	12.2	14.4	11.7	11.2	12.1	9.0	10.3	9.7	9.1	8.4	11.0	12.1	12.0	12.6	14.2	13.3	5 NTU	11.9
P.H.	8.0	7.9	7.9	7.8	7.7	7.8	7.8	7.9	7.9	7.6	8.0	7.9	7.7	8.0	7.9	8.0	7.8	7.9	8.0	7.9	7.9	6.5-8.5	7.9
ALCALINIDAD TOTAL	88	80	80	110	106	94	130	146	130	90	112	140	118	128	126	128	90	122	118	110	120		109.8
DUREZA TOTAL	278	244	280	270	288	240	290	282	266	274	260	280	300	290	286	276	254	286	294	286	258	500 MG/LT	275.3
CLORUROS	190	175	195	195	206	187	190	183	194	192	194	185	200	202	230	191	180	200	214	185	173	250 MG/LT	193.4
CLORO RESIDUAL																							
CALCIO	130	104	120	110	110	190	200	208	226	190	160	186	190	212	180	198	186	192	180	168	178		173.2
MAGNESIO	148	140	160	160	178	50	90	74	42	84	100	94	110	78	106	78	88	94	114	98	78		102.1
SDT	465	478.5	470	473.5	495	473	476.5	475	478	472	460	475	484.5	484.5	487	474	495	496	505	482	460	1000 MG/LT	478.8

Realizó



**QFA MIRIAM CAVAZOS GARCIA**  
**JEFE DE LABORATORIO**

Vo. Bo.



**BQF JUAN GUILLERMO NAVA LUJANO**  
**COORDINADOR DE CALIDAD DEL AGUA**