



• REYNOSA  
• TAMAUJIPAS  
GOBIERNO DEL ESTADO DE TAMAULIPAS

• COMAPA  
REYNOSA  
Comisión Municipal de Agua Potable y  
Alcantarillado del Municipio de Reynosa



TODOS POR  
TAMAUJIPAS

## PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS  
AGUA CRUDA  
MARZO 2016

FECHA:	1	2	4	7	8	9	10	11	14	15	16	17	18	22	23	28	29	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	9.2	14.0	11.3	16.0	9.8	18.0	13.0	11.8	6.8	8.0	9.8	9.8	13.7	9.8	10.4	16.0	16.7	18.5	21.5	5 NTU.	12.8
P.H.	7.6	7.7	7.6	7.6	7.8	7.8	7.8	7.7	7.8	7.7	7.8	7.8	7.7	7.7	7.8	7.7	7.8	7.7	7.8	6.5-8.5	7.7
ALCALINIDAD TOTAL	94	92	88	88	88	84	94	90	90	92	86	90	82	90	82	106	104	90	100		91.1
DUREZA TOTAL	340	342	308	312	352	300	310	298	312	284	286	290	330	316	332	380	348	330	360	500 MG/LT	322.6
CLORUROS	158	160	133	115	142	135	127	129	126	141	140	142	150	130	148	171	152	168	158	250 MG/LT	143.4
CALCIO	146	148	180	176	182	160	164	172	162	174	172	174	180	190	164	234	222	180	230		178.4
MAGNESIO	194	194	128	136	170	140	146	126	150	110	114	116	150	126	168	146	126	170	130		144.2
SDT	563.5	555	499	535	548	540	525	527	508	535	490	550	555	537.5	560	497	549	544	519	1000 MG/LT	534.6

QFB MIRIAM SÁVIZOS GARCÍA  
JEFE DE LABORATORIO.

BIOLOGO GUILTERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA