



• REYNOSA  
• TAMAUlipAS  
GOBIERNO DEL ESTADO

• COMAPA  
REYNOSA  
Comisión Municipal de Agua Potable y  
Aseo Urbano del Municipio de Reynosa

TODOS POR  
TAMAUlipAS

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS  
AGUA POTABLE  
ABRIL 2016

FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.2	3.5	4.8	4.6	2.5	2.9	2.9	5.0	5.0	5.0	5.0	3.9	5.0	2.6	5.0	4.8	5.0	5.0	5.0	4.6	4.3	5 NTU.	4.3
P.H.	7.2	7.2	7.2	7.4	7.4	7.4	7.4	7.2	7.4	7.3	7.4	7.2	7.2	7.4	7.3	7.3	7.1	7.1	7.4	7.1	7.3	6.5-8.5	7.3
ALCALINIDAD TOTAL	104	76	80	92	84	80	74	84	84	82	80	90	70	74	70	74	70	86	74	80	82		80.5
DUREZA TOTAL	320	300	322	330	310	340	330	320	318	314	320	310	270	294	320	322	268	290	320	324	330	500 MG/LT	313.0
CLORUROS	155	166	156	158	162	154	130	151	155	152	156	147	155	158	158	160	160	165	164	177	180	250 MG/LT	158.0
CLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1	1.2	1.4	1.5	1.3	1.3	1	1.1	1.2	1.1	1.4	1	1.3	1.2	1.4	0.2-1.5 MG/LT	1.3
CALCIO	158	170	172	180	170	190	172	164	170	160	170	166	132	136	170	170	176	160	180	194	190		169.0
MAGNESIO	162	130	150	150	140	150	158	156	148	154	150	144	138	158	150	152	92	130	140	130	140		143.9
SDT	530	535	545	550	500	535	530	560	545	565	555	557	545	562.5	562.5	575	585	570	585	610	620	1000 MG/LT	558.2

QFB. MIRIAM CAVAZOS GARCIA  
JEFE DE LABORATORIO.

No.186.  
GUILLERMO NAVA LUJANO  
COORDINADOR DE CALIDAD DEL AGUA