



PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
MARZO 2015

FECHA:	2	3	4	5	6	9	10	11	12	13	17	18	19	20	23	24	25	26	27	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	16.3	13.1	14.5	15.1	14.2	12.0	12.4	9.9	9.9	10.6	8.2	7.9	7.5	7.1	8.9	8.8	7.9	8.3	9.5	9.1	9.6	5 NTU.	10.5
P.H.	7.7	7.7	7.7	7.7	7.9	7.7	8	7.8	7.7	7.8	8	7.7	8	8	8	7.9	7.9	8	7.8	7.7	7.8	6.5-8.5	7.8
ALCALINIDAD TOTAL	120	124	130	136	130	126	120	134	154	148	130	140	140	150	144	146	144	152	144	134	132		137.0
DUREZA TOTAL	392	400	380	396	376	380	350	380	370	348	390	380	386	396	398	370	396	408	426	426	422	500 MG/LT	389.0
CLORUROS	170	160	185	190	173	178	186	175	170	175	175	117	180	180	193	205	200	217	216	213	212	250 MG/LT	184.3
CALCIO	260	230	208	232	224	220	230	230	230	230	220	226	210	210	220	232	220	252	274	250	272		231.9
MAGNESIO	142	170	172	164	152	160	120	150	140	118	170	154	176	186	880	138	176	156	152	176	150		181.0
SDT	672	684	683	673	686	685	681	688	681	669	669	666	665	674	672	723	745	740	729	734	741	1000 MG/LT	693.3

QFB MIRIAM CAVAZOS SAEZ
ENCARGADA DE LABORATORIO.

Vo.Bo.

ROBERTO LUJANO
COORDINADOR DE CALIDAD DEL AGUA