



● REYNOSA
● TAMAUlipas
● GOBIERNO DEL ESTADO

● COMAPA
● REYNOSA
Comisión Municipal de Agua Potable y
Alcantarillado del Municipio de Reynosa



TODOS POR
TAMAUlipas

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA CRUDA
ABRIL 2016

RESULTADOS EN MG/LT																													
FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO						
TURBIDEZ N.T.U.	23.5	29.4	28.4	24.9	33.7	28.7	63.5	61.2	64.3	59.7	56.0	36.0	38.0	34.6	29.3	20.0	18.4	14.2	21.2	16.4	13.5	5 NTU	34.0						
P.H.	7.7	7.8	7.7	7.7	7.9	7.7	7.7	7.8	7.7	7.7	7.8	7.7	7.6	7.7	7.7	7.6	7.8	7.7	7.7	7.8	7.7	6.5-8.5	7.7						
ALCALINIDAD TOTAL	96	96	80	94	86	82	84	96	98	96	98	88	84	86	76	78	80	86	84	82	80		87.1						
DUREZA TOTAL	320	310	308	334	316	306	300	324	330	332	338	284	284	290	314	310	252	286	303	342	348	500 MG/LT	311.0						
CLORUROS	155	164	141	149	146	150	128	137	139	140	180	135	135	140	142	148	140	151	152	174	175	250 MG/LT	148.6						
CALCIO	158	160	176	170	186	180	128	160	160	170	158	166	110	120	160	160	194	138	160	162	170		159.4						
MAGNESIO	162	150	132	164	130	126	172	164	170	162	180	116	174	170	154	150	58	148	143	180	178		151.6						
SDT	530	515	533	540	538	540	525	525	535	539	525	541.5	535	540	555	562.5	575	547	570	600	605	1000 MG/LT	546.4						

QEB MIRIAM BAVAZOS GARCÍA
JEFE DE LABORATORIO.

BIODOR GUATEMOTNAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA