



• REYNOSA
• TAMAUJIPAS
• GOBIERNO DEL ESTADO DE TAMAUJIPAS

• COMAPA
• R E Y N O S A
Comisión Municipal de Agua Potable
Asesoriada por el Municipio de Reynosa

TODOS
TAMAUL
|

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA POTABLE
MAYO 2016

FECHA:	2	3	4	5	6	9	10	11	12	13	16	17	18	19	20	23	24	25	26	27	30	31	NOM127/94	PROMEDIO
TURBIEDAD N.T.U.	4.2	4.0	4.2	4.5	4.1	5.0	4.9	5.0	4.9	5.0	5.0	4.9	5.0	5.1	4.9	5.0	4.6	5.0	5.0	3.4	4.7	5.0	5 NTU.	4.7
P.H.	7.3	7.4	7.4	7.5	7.4	7.5	7.4	7.5	7.4	7.4	7.4	7.5	7.3	7.4	7.4	7.4	7.4	7.4	7.6	7.4	7.4	7.5	6.5-8.5	7.4
ALCALINIDAD TOTAL	80	80	64	72	70	80	74	78	70	72	74	80	90	88	84	86	74	86	78	86	80	92		79.0
DUREZA TOTAL	312	316	306	320	330	298	288	326	328	306	296	284	310	316	330	338	382	406	348	350	350	370	500 MG/LT	328.8
CLORURO	170	169	149	167	169	150	157	163	165	158	157	160	172	176	209	235	238	237	236	227	236	213	250 MG/LT	187.0
CLORO RESIDUAL	1.4	1.0	1.4	1.1	1.5	1.0	1.4	1.2	1.5	1.5	1.5	1.5	1.1	1.5	1.4	1.0	1.2	1.4	1.5	1.1	1.5	1.1	0.2-1.5 MG/LT	1.3
CALCIO	196	198	180	200	180	188	170	188	190	164	110	130	160	198	190	240	194	194	204	224	170	180		184.0
MAGNESIO	116	118	126	120	150	110	118	138	138	142	186	134	150	118	140	98	188	212	144	126	180	190		142.8
SDT	620	605	605	600	590	595	585	575	595	595	580	560	595	650	695	735	765	762.5	735	700	720	735	1000 MG/LT	645.3

OFS MIRIAM OAVAZOS GARCIA
JEFE DE LABORATORIO.

Vo.Bo.
BIOTAYO GUILLERMO NAVAJA LUJANO
COORDINADOR DE CALIDAD DEL AGUA