

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS  
 AGUA POTABLE  
 ABRIL 2015

RESULTADOS EN MG/LT

FECHA:	1	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	4.2	5.0	4.7	4.5	4.2	4.7	4.1	5.0	4.4	4.2	4.9	5.0	5.0	5.0	5.0	5.0	4.6	4.3	2.7	3.3	5 NTU.	4.5
P.H.	7.7	7.8	7.5	7.5	7.5	7.4	7.7	7.6	7.6	7.5	7.6	7.5	7.7	7.5	7.5	7.6	7.4	7.5	7.5	7.3	6.5-8.5	7.5
ALCALINIDAD TOTAL	138	148	130	140	136	132	116	138	120	130	144	130	128	118	116	110	110	112	98	106		125.0
DUREZA TOTAL	366	380	386	382	380	382	454	490	386	372	470	398	410	390	396	402	350	402	372	414	500 MG/LT	399.1
CLORUROS	226	212	260	218	220	215	248	244	247	236	227	210	221	196	186	198	198	197	225	181	250 MG/LT	218.3
CLORO RESIDUAL	1.5	1.3	1.2	1.1	1.1	1.5	1.5	1.5	1.2	1.3	1.2	1.1	1	1.1	1.3	1.5	1.5	1.5	1.4	1.4	0.2-1.5 MG/LT	1.3
CALCIO	270	230	240	230	240	238	266	282	220	220	296	220	258	200	220	234	204	260	258	268		242.8
MAGNESIO	96	150	146	152	140	144	186	208	166	152	174	178	152	190	176	168	146	142	114	146		156.3
SDT	764	740	785	780	790	830	824	784	823	784	743	689	740	724	683	709	644	672	690	691	1000 MG/LT	744.5

  
 QFB MIRIAM CAVAZOS GARCIA  
 ENCANSADA DE LABORATORIO.

  
 Vo.Bp.  
 BIÓLOGO GUILLERMO NAVA LUJANO  
 COORDINADOR DE CALIDAD DEL AGUA