

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS AGUA POTABLE MAYO 2015

RESULTADOS EN MG/LT

FECHA:	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	3.3	4.4	3.5	3.4	3.5	4.8	5.0	4.9	5.0	5.0	4.9	4.0	5.0	4.9	4.6	5.0	4.9	5.0	5.0	4.9	5 NTU.	4.6
P.H.	7.5	7.6	7.6	7.6	7.3	7.3	7.5	7.3	7.3	7.6	7.2	7.4	7.2	7.5	7.5	7.7	7.5	7.4	7.6	7.4	6.5-8.5	7.5
ALCALINIDAD TOTAL	108	110	110	128	126	108	120	100	106	126	118	132	140	132	104	108	112	138	120	130		118.8
DUREZA TOTAL	374	396	396	390	374	380	390	388	312	424	420	372	410	394	348	340	364	348	334	336	500 MG/LT	373.5
COLORUBOS	160	198	208	210	210	200	200	185	160	210	188	203	210	247	220	174	163	180	163	165	250 MG/LT	192.7
COLORO RESIDUAL	1.5	1.5	1.5	1.5	1.5	1.5	1.4	1.5	1.5	1.4	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	0.2-1.5 MG/LT	1.5
CALCIO	238	230	220	200	224	206	216	218	186	250	244	244	284	262	220	240	216	218	160	156		221.6
MAGNESIO	136	166	166	180	150	174	174	170	126	174	176	128	126	132	128	100	148	130	174	180		151.9
SDT	723	705	731	715	753	710	716	707	707	671	689	690	718	734	725	608	624	607	610	600	1000 MG/LT	687.2


GEB. MERIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.

Vo.Bo.

BIOLOGO GUILLERMO DAZA TULLANO
COORDINADOR DE CALIDAD DEL AGUA