

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS

AGUA CRUDA

MAYO 2015

RESULTADOS EN MG/LT

FECHA:	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	20.8	17.9	19.0	26.2	15.2	30.4	28.8	96.8	96.8	240.0	39.0	30.1	23.1	25.6	29.4	94.9	94.1	160.0	106.0	96.5	5 NTU.	64.0
P.H.	7.5	7.5	7.9	7.3	7.6	7.6	7.5	7.4	7.4	7.7	7.6	7.6	7.8	7.6	7.8	7.5	7.7	7.7	7.4	7.5	6.5-8.5	7.6
ALCALINIDAD TOTAL	126	120	130	140	130	142	128	136	190	158	116	128	144	142	110	126	116	132	140	140		134.7
DUREZA TOTAL	360	360	404	410	380	380	398	390	348	440	424	420	428	400	356	420	340	374	342	340	500 MG/LT	385.7
CLORUROS	165	196	198	200	205	195	180	180	1956	185	185	220	205	200	257	160	180	153	172	170	250 MG/LT	278.1
CALCIO	240	266	230	180	220	220	240	210	190	256	280	270	232	232	200	220	230	222	172	192		225.1
MAGNESIO	120	94	174	230	160	160	158	180	158	184	144	150	196	168	156	200	110	152	170	148		160.6
SDT	690	700	705	720	748	704	698	677	677	657	688	689	705	698	735	615	602	594	605	609	1000 MG/LT	675.8


QFB MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.


Vg/Bc.
BIOLOGO GUILLERMO AYA LUJANO
COORDINADOR DE CALIDAD DEL AGUA