


PLANTA POTABILIZADORA PASTOR LOZANO
ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
ago-17

RESULTADOS EN MG/LT


FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	31	NOM-127/94	PROMEDIO	
TURBIEDAD N.T.U.	4.3	5.0	4.6	5.0	5.0	4.6	3.9	5.0	5.0	4.0	3.9	3.9	4.7	4.4	5.0	5.0	3.1	5.0	4.6	4.7	3.7	4.2	5.0	5 NTU.	4.5	
P.H.	7.7	7.6	7.6	7.6	7.5	7.5	7.5	7.5	7.6	7.6	7.5	7.6	7.7	7.7	7.6	7.5	7.5	7.5	7.5	7.4	7.5	7.4	7.5	7.5	6.5-8.5	7.5
ALCALINIDAD TOTAL	100	94	94	98	84	110	114	96	120	118	112	124	96	106	104	98	108	120	126	102	148	118	154		110.8	
DUREZA TOTAL	300	320	320	324	318	300	330	300	324	310	298	320	326	334	310	326	316	334	312	302	288	350	352	500 MG/LT	317.9	
CLORUROS	239	244	237	243	232	218	233	233	242	190	226	235	239	246	250	247	247	270	247	229	218	255	257	250 MG/LT	238.3	
CLORO RESIDUAL	1	1	1.1	1.1	1.1	1	1.2	1.2	1.2	1	1	1.1	1	1	1	1.5	1.5	1.1	1.5	1.5	1	1.5	1.5		1.2	
CALCIO	182	204	176	194	170	170	188	196	200	200	184	186	196	182	162	204	220	184	204	170	182	214	166		188.5	
MAGNESIO	118	116	142	130	148	130	142	104	124	110	114	134	130	152	148	122	96	150	108	132	104	136	186		129.4	
SDT	545	556.5	551.5	559.5	532.5	512.5	549.5	522	580	550	568	557.5	569.5	563.5	571	587.5	572	570	567	535	557	610	602.5	1000 MG/LT	560.5	

Realizó



QFB MIRIAM CAVAZOS GARCIA
 JEFE DE LABORATORIO

Vp-80.



BIOL. JUAN GUILLERMO NAVA LUJANO
 COORDINADOR DE CALIDAD DEL AGUA