

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
JUNIO 2015

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	5.0	5.0	5.0	5.0	4.2	4.4	5.0	4.2	5.0	5.0	5.0	5.0	4.5	5.0	5.0	5.0	4.7	4.7	3.5	4.9	5.0	5.0	5 NTU.	4.8
P.H.	7.4	7.2	7.4	7.5	7.4	7.4	7.5	7.4	7.5	7.4	7.5	7.5	7.5	7.4	7.3	7.7	7.6	7.6	7.4	7.3	7.5	7.3	6.5-8.5	7.4
ALCALINIDAD TOTAL	118	116	126	130	126	102	120	118	122	118	110	120	104	108	104	98	94	124	90	102	100	108		111.7
DUREZA TOTAL	320	320	320	348	362	320	340	340	362	374	276	320	324	358	304	326	310	300	284	310	274	328	500 MG/LT	323.6
COLORUROS	150	165	148	153	162	155	180	183	175	171	160	153	136	152	142	163	170	158	184	150	160	156	250 MG/LT	160.3
COLORO RESIDUAL	1.5	1.5	1.5	1.5	1.4	1.5	1.4	1.5	1.5	1.5	1.5	1.44	1.53	1.3	1.5	1.5	1	1.5	1.5	1.5	1.5	1.5	0.2-1.5 MG/LT	1.5
CALCIO	170	184	200	198	228	200	190	232	248	254	200	180	210	168	170	224	180	170	100	220	160	180		193.9
MAGNESIO	150	136	120	150	134	120	150	108	114	120	76	140	114	190	134	102	130	130	184	90	114	148		129.7
SDI	580	574	539	563	589	603	641	597	617	582	565	585	534.5	540	542	584	571	587	562	554	542	542	1000 MG/LT	572.4


GEB. MIRIAM CAVAZOS GARZA
ENCARGADA DE LABORATORIO.


Yo Be
GREGORIO QUIJERO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA