

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS  
AGUA CRUDA  
JUNIO 2015

RESULTADOS EN MG/LT

FECHA:	1	2	3	4	5	8	9	10	11	12	15	16	17	18	19	22	23	24	25	26	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	185.0	121.0	112.0	64.7	41.6	25.0	28.6	30.7	30.1	30.7	26.0	28.4	33.7	36.7	31.7	32.6	33.9	31.5	34.2	30.2	24.0	22.3	5 NTU.	46.9
P.H.	7.7	7.7	7.7	7.6	7.6	7.7	7.9	7.6	7.9	7.6	7.8	7.6	7.7	7.7	7.6	7.9	7.8	7.6	7.6	7.6	7.9	8	6.5-8.5	7.7
ALCALINIDAD TOTAL	136	140	130	132	148	112	126	132	140	120	130	130	126	102	114	100	114	120	106	116	110	126		123.2
DUREZA TOTAL	330	340	316	340	358	304	346	346	380	372	324	310	320	350	336	320	320	310	290	310	290	320	500 MG/LT	328.7
CLORUROS	138	150	145	150	154	140	164	162	165	156	150	146	130	148	140	160	160	138	210	143	140	150	250 MG/LT	151.8
CALCIO	180	160	178	180	236	184	194	216	256	234	210	190	208	176	160	220	172	180	150	174	150	190		190.8
MAGNESIO	150	180	138	160	122	120	152	130	124	138	114	120	112	174	176	100	148	130	140	136	140	130		137.9
SDT	549	549	527	556	564	580	600	600	635	592	541	562	514	522	527	543	553	565	562	504.2	542	544.5	1000 MG/LT	556.0

  
OFB MIRIAM CAVAZOS GARCIA  
ENCARGADA DE LABORATORIO.

Vo.Bo.  
  
BIÓLOGO GUILLERMO NAVA LUANG  
COORDINADOR DE CALIDAD DEL AGUA