

## PLANTA POTABILIZADORA PASTOR LOZANO

### ANÁLISIS FÍSICOQUÍMICOS AGUA POTABLE JULIO 2015

FECHA:	1	2	3	6	7	8	9	10	13	14	15	16	17	20	21	22	23	24	27	28	29	30	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	7.0	4.6	4.6	2.9	5.0	5.0	5.0	7.1	4.9	5.3	6.8	6.9	5.0	6.5	4.4	3.6	3.8	4.0	5.9	5.4	5.6	5.6	5.8	5 NTU	5.2
P.H.	7.6	7.6	7.7	7.5	7.7	7.5	7.5	7.6	7.6	7.6	7.8	7.5	7.6	7.5	7.6	7.6	7.5	7.5	7.5	7.4	7.5	7.5	7.6	6.5-8.5	7.6
ALCALINIDAD TOTAL	110	118	114	106	112	110	108	126	118	102	102	108	94	88	100	104	100	100	88	92	104	100	86		103.9
DUREZA TOTAL	310	310	302	320	294	282	280	264	280	284	330	268	286	290	320	314	306	288	298	304	310	312	180	500 MG/LT	292.7
CLORUROS	150	156	162	169	158	163	156	148	138	142	144	146	146	124	156	144	143	146	130	134	138	136	109	250 MG/LT	145.1
CLORO RESIDUAL	1.5	1.3	1.6	1.4	1.7	1.6	2.2	1.5	1.7	1.6	1.7	1.43	1.27	1.62	1.46	1	1.43	1.26	1.6	1.4	2.1	1.3	1.4	0.2-1.5 MG/LT	1.5
CALCIO	180	170	220	200	160	176	190	150	180	142	224	196	198	170	160	190	198	166	176	182	188	182	186		181.0
MAGNESIO	130	140	82	120	134	106	90	114	100	142	106	72	88	120	160	124	108	122	122	122	122	130	14		111.7
SDT	571	582	587	465	534.5	512	521	516.5	487	525	507.5	520	506	481	468	480	490	484	475	620	540	540	565	1000 MG/LT	520.8

*[Signature]*  
Q.F.B. MIRIAM CAVAZOS GARCÍA  
ENCARGADA DE LABORATORIO.

Vo Bo  
*[Signature]*  
BIÓLOGO GILBERTO NAVA LOZANO  
COORDINADOR DE CALIDAD DEL AGUA