

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS AGUA CRUDA AGOSTO 2015

FECHA:	3	4	5	6	7	10	11	12	13	14	17	18	19	20	21	24	25	26	27	28	31	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	30.2	24.2	28.8	26.6	25.5	32.2	23.3	25.4	24.0	21.2	23.5	24.0	19.2	15.8	22.6	13.0	12.6	13.0	13.1	9.9	11.8	5 NTU.	20.9
P.H.	7.8	7.7	7.8	7.7	7.7	7.5	7.6	7.7	7.7	7.6	7.7	7.6	7.5	7.5	7.7	7.6	7.7	7.5	7.5	7.5	7.7	6.5-8.5	7.6
ALCALINIDAD TOTAL	82	90	100	110	86	110	102	110	100	120	106	120	116	110	110	104	108	94	120	110	110		105.6
DUREZA TOTAL	232	300	268	320	278	360	280	260	310	250	284	228	270	280	280	300	302	280	286	266	280	500 MG/LT	281.6
CLORUROS	90	135	143	115	130	140	115	115	125	125	115	120	140	125	125	150	135	140	150	145	140	250 MG/LT	129.4
CALCIO	120	180	140	170	168	140	148	170	170	130	160	140	160	140	130	160	160	160	180	186	198		157.6
MAGNESIO	112	120	128	150	110	220	132	90	140	120	124	88	110	140	150	140	142	120	106	80	82		124.0
SDT	506	508	502	499.5	489.5	515	480	480	501	475	481	475	477	500	505	536	564	546	546	557	571	1000 MG/LT	510.2


GERARDO MIRIAM CAVAZOS GARCHA
ENCARGADA DE LABORATORIO.


BIÓLOGO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA

Vo.Bo.