

PLANTA POTABILIZADORA PASTOR LOZANO

ANÁLISIS FÍSICOQUÍMICOS
AGUA POTABLE
SEPTIEMBRE 2015

RESULTADOS EN MG/LT																														
FECHA:	1	2	3	4	7	8	9	10	11	14	15	17	18	21	22	23	24	25	28	29	30	NOM-127/94	PROMEDIO							
TURBIEDAD N.T.U.	2.6	2.1	5.0	3.7	3.3	3.7	4.6	3.0	4.1	4.7	3.2	2.3	2.0	2.9	2.8	2.9	3.1	2.2	3.0	2.9	2.5	5 NTU.	3.2							
P.H.	7.4	7.3	7.4	7.4	7.3	7.3	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.6	6.5-8.5	7.4							
ALCALINIDAD TOTAL	114	124	112	120	116	136	134	120	118	98	92	118	114	100	104	102	108	104	100	116	118		112.8							
DUREZA TOTAL	356	350	330	308	330	320	316	320	298	262	274	250	288	270	268	286	310	290	288	316	298	500 MG/LT	301.3							
CLORUROS	178	190	185	180	167	117	166	171	174	117	143	144	164	157	161	173	164	169	172	194	213	250 MG/LT	167.5							
CLORO RESIDUAL	1.5	1.4	1.1	1.5	1.1	1.2	1.1	1.5	1.1	1.5	1.5	1.5	1.5	1.4	1.4	1.4	1.3	1.4	1.5	1.4	1.1	0.2-1.5 MG/LT	1.4							
CALCIO	188	230	216	208	196	210	222	130	180	172	190	154	180	170	174	176	188	192	196	202	198		189.1							
MAGNESIO	168	120	114	152	134	110	94	190	118	90	84	96	108	100	94	110	122	98	92	114	100		114.7							
SDT	590	625	632	592	631	592	615	581	562.5	512	542	547	561	594	580	582.5	605	602	641.5	650	657.5	1000 MG/LT	594.5							


QFB. MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.


BOLFO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA