

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS AGUA CRUDA SEPTIEMBRE 2015

FECHA:	1	2	3	4	7	8	9	10	11	14	15	16	17	18	21	22	23	24	25	28	29	30	NOM-127/94	PROMEDIO
TURBIEDAD N.T.U.	12.1	12.7	14.8	18.5	16.8	15.3	17.0	14.3	15.2	17.5	14.5		18.1	13.2	11.4	12.9	12.3	10.6	14.9	15.7	17.9	16.8	5 NTU.	14.9
P.H.	7.5	7.5	7.5	7.3	7.5	7.5	7.7	7.4	7.6	7.5	7.6		7.3	7.4	7.5	7.5	7.3	7.4	7.4	7.5	7.5	7.6	6.5-8.5	7.5
ALCALINIDAD TOTAL	122	120	116	130	108	128	130	132	112	110	110		112	114	120	112	114	110	104	98	126	132		117.1
DUREZA TOTAL	350	390	354	292	310	296	304	272	294	254	276		280	284	316	300	306	276	278	288	320	366	500 MG/LT	305.0
CLORUROS	170	180	170	160	173	176	167	173	160	133	148		145	155	145	161	150	164	175	173	183	220	250 MG/LT	165.8
CALCIO	200	220	220	200	198	200	192	172	186	190	162		158	192	198	192	178	182	188	158	182	140		186.1
MAGNESIO	150	170	134	92	112	96	112	100	108	64	114		122	92	118	108	128	94	90	130	138	226		119.0
SDT	584	620	615	557	621	607	577	561	535	511	528		545	560	575	562.5	600	600	594	637.5	644	652	1000 MG/LT	585.0


O.F.B. MIRIAM CAVAZOS GARCIA
ENCARGADA DE LABORATORIO.


Vo.Bo
RIGOBERTO GUILLERMO NAVA LUJANO
COORDINADOR DE CALIDAD DEL AGUA