

PLANTA POTABILIZADORA PASTOR LOZANO

ANALISIS FISICOQUIMICOS
AGUA CRUDA
JULIO 2016

RESULTADOS EN MG/LT																													
FECHA:	1	4	5	6	7	8	11	12	13	14	15	18	19	20	21	22	25	26	27	28	29	NOM-127/94	PROMEDIO						
TURBIEDAD N.T.U.	18.8	17.6	19.7	16.4	16.7	14.6	15.9	18.7	17.3	19.8	14.6	19.7	23.3	19.7	17.2	16.7	16.4	17.8	21.0	19.5	20	5 NTU.	18.2						
P.H.	7.7	7.6	7.5	7.4	7.6	7.6	7.6	7.6	7.6	7.6	7.6	7.5	7.5	7.6	7.4	7.6	7.6	7.2	7.6	7.5	7.5	6.5-8.5	7.5						
ALCALINIDAD TOTAL	74	68	56	66	90	80	78	60	70	72	64	60	70	72	66	72	70	60	60	80	76		69.7						
DUREZA TOTAL	276	240	352	328	300	300	272	282	258	284	288	320	290	290	280	278	258	294	284	298	310	500 MG/LT	289.6						
CLORUROS	147	140	137	167	160	170	144	138	144	154	149	160	155	158	156	155	157	159	217	238	234	250 MG/LT	163.9						
CALCIO	150	166	242	224	200	160	154	144	150	148	136	224	122	162	152	162	122	150	140	140	152		161.9						
MAGNESIO	126	74	110	104	100	140	118	138	108	136	152	96	168	128	128	116	136	144	144	158	158		127.7						
SDT	530	515	535	544	545	515	508	536	550	541	515	511	528	531	531	534	505	548	555	564	559	1000 MG/LT	533.3						


OFB. MIRIAM SAAVIZOS GARCIA
JEFE DE LABORATORIO.

No. Bo. 
BIOLOGO GUILLERMO NAVARELLANO
COORDINADOR DE CALIDAD DEL AGUA